


Building Energy Performance		Scotland	
<b>Energy Performance Certificate</b>	Calculated asset rating using Carbon Checker v1.5 [SBEM]	Building type Further education universities	<b>Current rating</b>
			<b>Excellent</b>
	<b>Carbon Neutral</b>		
	<b>A (0 to 15)</b>		
	<b>B (16 to 30)</b>		
	<b>C (31 to 45)</b>		
	<b>D (46 to 60)</b>		
	<b>E (61 to 80)</b>		<b>E+</b>
	<b>F (81 to 100)</b>		
	<b>G (100+)</b>		<b>Very Poor</b>
<b>Carbon Dioxide Emissions</b> The number refers to the calculated carbon dioxide emissions in terms of kg per m <sup>2</sup> of floor area per year		<b>69</b>	
Approximate current energy use per m <sup>2</sup> of floor area:		<b>299 kWh/m<sup>2</sup></b>	
Main heating fuel: Natural Gas Renewable energy source:		Building Services: Heating with Nat. Vent. Electricity: Grid supplied	
<b>Carbon Dioxide is a greenhouse gas which contributes to climate change.                      Less Carbon Dioxide emissions from buildings helps the environment.</b>			
<b>Benchmarks</b>			
A building of this type built to building regulations standards current at the date of issue of this certificate would have a rating:		<b>25</b>  <b>B</b>	
Where the accompanying recommendations for the cost effective improvement of energy performance are applied, this building would have a rating:		<b>53</b>  <b>D</b>	
<b>Recommendations for the cost-effective improvement (lower cost measures) of the energy performance</b>			
1. Some spaces have a significant risk of overheating. Consider solar control measures such as the application of reflective coating or shading devices to windows.			
2. Consider replacing T8 lamps with retrofit T5 conversion kit.			
3. Consider replacing heating boiler plant with high efficiency type.			
4. Add optimum start/stop to the heating system.			
5. The default heat generator efficiency is chosen. It is recommended that the heat generator system be investigated to gain an understanding of its efficiency and possible improvements.			
6. Introduce HF (high frequency) ballasts for fluorescent tubes: Reduced number of fittings required.			

**Address:** Goodleyburn Building, Perth College, Crieff Road, Perth, PH1 2NX

**Conditioned area (m<sup>2</sup>):** 6653

**Name of protocol organisation:** BRE Global, [BRE-ND-EPC0043]

**Date of issue of certificate:** 22 Feb 2011 (Valid for a period not exceeding 10 years)

This certificate is a requirement of EU Directive 2002/91/EC on the energy performance of buildings.

**NB THIS CERTIFICATE MUST BE AFFIXED TO THE BUILDING AND NOT REMOVED UNLESS REPLACED WITH AN UPDATED VERSION AND FOR PUBLIC BUILDINGS DISPLAYED IN A PROMINENT PLACE**